

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

TEST REPORT

Client : Flooring Distributers Australia
71 Forsyth Street
O'Connor WA 6163

Test Number : 21-001822
Issue Date : 4/05/2021
Print Date : 4/05/2021

Sample Description Clients Ref : "Comfortstone/Paramount Stone"
Luxury Vinyl Tile
Colour : Multi Colour
End Use : Flooring
Nominal Composition : PVC
Nominal Thickness : 4.5mm

AS 4586-2013
Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 04/05/2021
Test Temperature (20±5degC) 20 °C
Sample Preparation Sample washed with pH neutral detergent and dried
Test Direction Length
Fixed/Unfixed Unfixed
Slider No 96 Batch No 95
Length 1 2 3 4 5 SRV
British Pendulum Number 31 30 30 31 30 30
Classification P2

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

236162


51013


Page 1 of 1



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.




Chris Campbell
APPROVED SIGNATORY


MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR